

Potenza LV Distribution Grid Inverter Installation and Maintenance Record Sheets

Ref No.	Equipment Part No. / Description	Interval (Months)	Type of Inspection
6.1	Cleaning the Exterior of the Potenza LV DGI	3	Visual and clean
6.2	Air Ducts	3	Visual / clean as required
6.3	Enclosure and Doors	6	Visual
6.4	LED	12	Visual
6.5	HMI	12	Visual